

# PLYMOUTH FIRE PROTECTION

UNITS 94 & 95 CITY BUSINESS PARK, SOMERSET PLACE, STOKE, PLYMOUTH, DEVON, PL3 4FF

FIRE ALARM SYSTEM – SMOKE\HEAT DETECTION SYSTEM – EMERGENCY LIGHTING SYSTEM – SMOKE VENTILATION SYSTEM

## CERTIFICATE OF ATTENDANCE, INSPECTION, SERVICE, TEST & MAINTENANCE

<b>CLIENT NAME</b>	Student Life Lettings Ltd					
<b>SITE ADDRESS</b>	37 Beechwood Avenue, Plymouth, Devon, PL4 6PW					
<b>DATE OF VISIT</b>	Wednesday 9 <sup>th</sup> July 2023					
<b>REASON FOR ATTENDANCE</b>	<b>AUTOMATIC FIRE ALARM SYSTEM</b>	<b>SMOKE\HEAT DETECTION SYSTEM</b>	<b>EMERGENCY LIGHTING SYSTEM</b>	<b>SMOKE VENTILATION SYSTEM</b>		
6-Monthly						
12-Monthly	N/A	✓	N/A	N/A		
FAULT						
CALL OUT						
PARTIAL INSTALLATION FAULT RECTIFICATION						
Fire Alarm System Periodic Service\Maintenance\Certification in accordance with BS5839 Part 1 (as amended or updated)				X		
Smoke\Heat Detection System Service\Maintenance\Certification in accordance with BS5839 Part 6 (as amended or updated)				✓		
Emergency Lighting System Service\Maintenance\Certification in accordance with BS5266 Part 8 (as amended or updated)				X		
Smoke Ventilation System Service\Maintenance\Certification in accordance with BS7346 Part 8 (as amended or updated)				X		
<b>BATTERY DATE &amp; TEST RESULT</b>	Battery One: N/A Battery Two: N/A					
FIRE ALARM SYSTEM	N/A					
SMOKE\HEAT DETECTION SYSTEM	Grade D 230v Detection System Requires Upgrade Work					
EMERGENCY LIGHTING SYSTEM	N/A					
SMOKE VENTILATION SYSTEM	N/A					
<b>ENGINEER(S) REPORT \ COMMENTS:</b>						
System requires 2 x 1 x Aico Smoke Detectors and 1 x Aico Heat Detector. Aico/Dicon System comprises of 2 x Smoke Detectors and 1 x Heat Detector, a mixture between 9v Battery Back-up and 10 Year Lithium Battery Back-up Detection. Life expiry dates range between 2024/2029. System has been tested and serviced in accordance with BS5839 Part 6 2019. Next service due August 2024.						
FURTHER UPGRADE - COMPLIANCE WORK REQUIRED: <b>YES \ NO</b> (ENGINEER TO CONFIRM – PLEASE HIGHLIGHT IN RED)						
<b>COMPONENTS SUPPLIED</b>	<b>DAMAGED</b>	<b>LIFE EXPIRED</b>	<b>MISSING</b>	<b>FAULTY</b>	FIRE ALARM CONTROL PANEL	
FIKE APOLLO	HOCHIKI KAC	CALL POINT UNIT	BATTERY 9V	2	FIRE ANGEL 10YR \ 9V	DETECTOR\SOUNDER UNIT DETECTOR UNIT
AICO DICON	KIDDE OTHER	CALL POINT GLASS	BATTERY 12V ( ah)		OTHER 10YR \ 9V	EMERGENCY LIGHT LED UNIT (NM) EMERGENCY LIGHT LED UNIT (M)
FIRE ALARM KEY ISOLATOR	HEAT ( ) SMOKE ( )	SOUNDER UNIT	BASE ( ) RADIO ( )		EL TEST SWITCH	VENT\WINDOW ACTUATOR ACTUATOR CONTROL PANEL

ENGINEER NAME: JOSHUA FARLEY

ENGINEER TECHNICIAN SIGNATURE:

*J. Farley*