

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 21/08/2023 To: 25/08/2023

Client: 03 Student Life Lettings

Site: 5 FURZEHILL RD

Location: ROOMS

Asset ID: 5FR100	Description: POWER SUPPLY	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250
------------------	---------------------------	-----------	---

Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Overall: Pass				

Asset ID: 5FR101	Description: 2 GANG LEAD	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250
------------------	--------------------------	-----------	---

Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
IEC Lead Continuity	24/08/2023	0.04	ohm	Pass
IEC Lead Continuity	24/08/2023	0.03	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	24/08/2023			Pass
Overall: Pass				

Asset ID: 5FR102	Description: LEAD SET	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250
------------------	-----------------------	-----------	---

Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
IEC Lead Continuity	24/08/2023	0.07	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	24/08/2023			Pass
Overall: Pass				

Asset ID: 5FR103	Description: POWER SUPPLY	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250
------------------	---------------------------	-----------	---

Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Overall: Pass				

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 21/08/2023 To: 25/08/2023

Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Earth Continuity	24/08/2023	0.03	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 5FR104	Description: LEAD SET	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
IEC Lead Continuity	24/08/2023	0.1	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	24/08/2023			Pass
Overall: Pass				

Asset ID: 5FR105	Description: INTERNET DEVICE	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Earth Continuity	24/08/2023	0.07	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 5FR106	Description: POWER SUPPLY	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Overall: Pass				

Asset ID: 5FR107	Description: TV	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Overall: Pass				

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 21/08/2023 To: 25/08/2023

Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 5FR108	Description: LAMP	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 5FR109	Description: 4 GANG LEAD	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
IEC Lead Continuity	24/08/2023	0.1	ohm	Pass
IEC Lead Continuity	24/08/2023	0.06	ohm	Pass
IEC Lead Continuity	24/08/2023	0.06	ohm	Pass
IEC Lead Continuity	24/08/2023	0.06	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	24/08/2023			Pass
Overall: Pass				

Asset ID: 5FR111	Description: IRON	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Earth Continuity	24/08/2023	0.07	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Overall: Pass				

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 21/08/2023 To: 25/08/2023

Insulation	24/08/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 5FR114	Description: TOASTER	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Earth Continuity	24/08/2023	0.05	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 5FR116	Description: KETTLE / KETTLE BASE	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 5FR118	Description: 2 GANG LEAD	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
IEC Lead Continuity	24/08/2023	0.12	ohm	Pass
IEC Lead Continuity	24/08/2023	0.12	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	24/08/2023			Pass
Overall: Pass				

Asset ID: 5FR119	Description: FREEZER	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Overall: Pass				

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 21/08/2023 To: 25/08/2023

Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Earth Continuity	24/08/2023	0.09	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 5FR120	Description: WASHING MACHINE	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Earth Continuity	24/08/2023	0.1	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 5FR121	Description: FREEZER	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Earth Continuity	24/08/2023	0.16	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	8.35	MOhm	Pass
Overall: Pass				

Asset ID: 5FR122	Description: IRON	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Earth Continuity	24/08/2023	0.18	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 5FR123	Description: 3 GANG ADAPTER	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
------------------	-----------------------------	-----------	---	--

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 21/08/2023 To: 25/08/2023

Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
IEC Lead Continuity	24/08/2023	0.04	ohm	Pass
IEC Lead Continuity	24/08/2023	0.03	ohm	Pass
IEC Lead Continuity	24/08/2023	0.03	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	24/08/2023			Pass
				Overall: Pass

Asset ID: 5FR124	Description: TUMBLE DRYER	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Earth Continuity	24/08/2023	0.03	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 5FR128	Description: MICROWAVE	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Earth Continuity	24/08/2023	0.04	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 5FR129	Description: KETTLE/BASE	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
				Overall: Pass

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 21/08/2023 To: 25/08/2023

Voltage	24/08/2023	230	V	Information
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 5FR130	Description: FRIDGE	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 5FR131	Description: TOASTER	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Earth Continuity	24/08/2023	0.03	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 5FR132	Description: COOKER HOOD	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Earth Continuity	24/08/2023	0.05	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 5FR133	Description: FRIDGE	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Overall: Pass				

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 21/08/2023 To: 25/08/2023

Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Earth Continuity	24/08/2023	0.05	ohm	Pass
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 5FR134	Description: HOOVER	User: GJH	Test Instrument: Seaward Apollo 500 Plus 06N-1250	
Test Type	Date	Result	Unit	Status
Plug	24/08/2023			Pass
Flex	24/08/2023			Pass
Enclosure	24/08/2023			Pass
Environment	24/08/2023			Pass
Socket	24/08/2023			Pass
Switch	24/08/2023			Pass
Voltage	24/08/2023	230	V	Information
Insulation Voltage	24/08/2023	500	V	Information
Insulation	24/08/2023	> 19.99	MOhm	Pass
Overall: Pass				

Total Tests: 27