

# PLYMOUTH FIRE PROTECTION

UNITS 94&95 CITY BUSINESS PARK, SOMERSET PLACE, STOKE, PLYMOUTH, DEVON, PL3 4FF

FIRE ALARM SYSTEM – SMOKE\HEAT DETECTION SYSTEM – EMERGENCY LIGHTING SYSTEM – SMOKE VENTILATION SYSTEM

## CERTIFICATE OF ATTENDANCE, INSPECTION, SERVICE, TEST & MAINTENANCE

CLIENT NAME	Student Life Lettings Ltd				
SITE ADDRESS	5 Furzehill Road, Plymouth, Devon, PL4 7JY				
DATE OF VISIT	Monday 8 <sup>th</sup> July 2024				
REASON FOR ATTENDANCE	AUTOMATIC FIRE ALARM SYSTEM	SMOKE\HEAT DETECTION SYSTEM	EMERGENCY LIGHTING SYSTEM	SMOKE VENTILATION SYSTEM	
6-Monthly					
12-Monthly	N/A	✓	N/A	N/A	
FAULT					
CALL OUT					
PARTIAL INSTALLATION FAULT RECTIFICATION					
Fire Alarm System Periodic Service\Maintenance\Certification in accordance with BS5839 Part 1 (as amended or updated)				X	
Smoke\Heat Detection System Service\Maintenance\Certification in accordance with BS5839 Part 6 (as amended or updated)				✓	
Emergency Lighting System Service\Maintenance\Certification in accordance with BS5266 Part 8 (as amended or updated)				X	
Smoke Ventilation System Service\Maintenance\Certification in accordance with BS7346 Part 8 (as amended or updated)				X	
BATTERY DATE & TEST RESULT	Battery One: N/A Battery Two: N/A				
FIRE ALARM SYSTEM	N/A				
SMOKE\HEAT DETECTION SYSTEM	Grade D 230v Detection System Fully Operational				
EMERGENCY LIGHTING SYSTEM	N/A				
SMOKE VENTILATION SYSTEM	N/A				
<b>ENGINEER(S) REPORT \ COMMENTS:</b>					
Aico 230v System comprises of 3 x Smoke detectors, 1 x Heat detector and 3 x Radio Bases, all 9v Battery Back-up. Life expiry dates range between 2025/2029. System has been tested and serviced in accordance with BS5839 Part 6 2019. Next service due July 2025.					
FURTHER UPGRADE - COMPLIANCE WORK REQUIRED: YES \ NO (ENGINEER TO CONFIRM – PLEASE HIGHLIGHT IN RED)					
<b>COMPONENTS SUPPLIED</b> ✓	<b>DAMAGED</b>	<b>LIFE EXPIRED</b>	<b>MISSING</b>	<b>FAULTY</b>	FIRE ALARM CONTROL PANEL
FIKE APOLLO	HOCHIKI KAC	CALL POINT UNIT	BATTERY 9V	4 FIRE ANGEL 10YR \ 9V	DETECTOR\SOUNDER UNIT DETECTOR UNIT
AICO DICON	KIDDE OTHER	CALL POINT GLASS	BATTERY 12V ( ah)	OTHER 10YR \ 9V	EMERGENCY LIGHT LED UNIT (NM) EMERGENCY LIGHT LED UNIT (M)
FIRE ALARM KEY ISOLATOR	HEAT ( ) SMOKE ( )	SOUNDER UNIT	BASE ( ) RADIO ( )	EL TEST SWITCH	VENT\WINDOW ACTUATOR ACTUATOR CONTROL PANEL

ENGINEER NAME: JOSHUA FARLEY

ENGINEER TECHNICIAN SIGNATURE:

