

PLYMOUTH FIRE PROTECTION

UNIT 94 % 95 CITY BUSINESS PARK, SOMERSET PLACE, STOKE, PLYMOUTH, DEVON, PL3 4FF

FIRE EXTINGUISHER

ENGINEER ATTENDANCE SERVICE REPORT SHEET

CLIENT NAME	Student Life Lettings Ltd				
SITE ADDRESS	37 Beechwood Avenue, Plymouth, Devon, PL4 6PW				
DATE OF VISIT	Friday 19 th July 2024				
REASON FOR ATTENDANCE	ANNUAL CERTIFICATION ✓	REPLACEMENT	PARTIAL INSTALLATION	NEW INSTALLATION	
EQUIPMENT	1. 2KG ABC POWDER	2. 2KG ABC POWDER	3. FIRE BLANKET	4.	
5.	6.	7.	8.	9.	
10.	11.	12.	13.	14.	
15.	16.	17.	18.	19.	
20.	21.	22.	23.	24.	
Fire Extinguisher Service\Maintenance\Certification in accordance with BS5306 Part 3 (as amended or updated)				Y\N	
Replacement of Damaged\Faulty\Discharged Fire Extinguisher				Y\N	
Call Out Attendance				Y\N	
Survey for Initial Scaling				Y\N	
1kg\2kg\3kg\4kg\6kg\9kg ABC DRY POWDER	OTHER TYPE OF FIRE EXTINGUISHER (PLEASE LIST)				
2l\3l\6l\9l FOAM	FIRE BLANKET				
3l\6l\9l WATER – WATER ADDITIVE	IDENTIFICATION SIGNAGE DP () CO2 () WATER () FOAM () FIRE BLANKET () WC ()				
2kg\5kg CARBON DIOXIDE	PLASTIC MOULDED STAND SINGLE HS16 DOUBLE HS26 OTHER				
2l\3l\4l\6l\9l WET CHEMICAL	BRACKET				
THIS IS TO CERTIFY THAT THE FIRE EXTINGUISHER(S) LOCATED WITHIN THE SAID PREMISES HAVE EITHER BEEN SUPPLIED TO BSEN3 STANDARDS OR SERVICED IN ACCORDANCE WITH BRITISH STANDARD 5306 PART 3 (AS AMENDED or UPDATED) BY A SERVICE ENGINEER QUALIFIED TO A STANDARD APPROVED BY THE BRITISH STANDARDS INSTITUTION AND BRITISH APPROVALS FOR FIRE EQUIPMENT AS SATISFYING THE REQUIREMENTS OF QSP 94001 AND THE TRAINING CLAUSE OF ISO 9001					
ANTI-TAMPER SEAL	2	CHUBB PULL KEY	O RING SMALL	O RING LARGE	CO2 HORN O RING
DATE STICKER	3	PLASTIC DART	HOSE WATER	HOSE FOAM	HOSE DRY POWDER
CHROME PIN		PLASTIC NOZZLE	CO2 HORN	OTHER PULL KEY	PART:
PART:		PART:	PART:	PART:	PART:

ENGINEER NAME(S): Reiss Frost

ENGINEER SIGNATURE:

R. Frost